



**PEOPLE'S TELEVISION**  
P A R A S A B A Y A N

**People's Television Network, Inc**  
**Broadcast Complex, Visayas Avenue, Diliman, Quezon City 1100**  
**Telephone No. 3453-1097 /www.ptv.ph**

---

**BID BULLETIN NO. 2**  
3 December 2020

Waterproofing of Roof deck, Gutter and Third Floor Open Area Including Parapet and G.I Roof and Rehabilitation of Downspouts for People's Television Network, Inc. (PTNI) Main Building

**ITB NO. 2020-0025**

This bulletin is being issued to revise/clarify certain portions of the bidding documents, address a number of concerns and questions. This shall form an integral part of the bidding document for the above-stated project.

Item No.	Comments/Queries/Concerns	Final Response
1	Regarding the downspout, can we conduct ocular inspection? Are there any requirements needed before entering your office?	Please check Bid Bulletin No. 1
2	With regards to the G.I roof, is it full coat or not?	The contractor shall apply waterproofing material on the portions where there is/are leak/s.

All other information in the bidding document inconsistent with the above are hereby revised accordingly. All other provisions which are not affected shall remain in effect.

For further guidance and information of all concerned.

Thank you.

  
**ATTY. JASON H. SALENDAB**  
Chairman  
Bids and Awards Committee