



PEOPLE'S TELEVISION
P A R A S A B A Y A N

People's Television Network, Inc
Broadcast Complex, Visayas Avenue, Diliman, Quezon City 1100
Telephone No. 3453-1097 /www.ptv.ph

BID BULLETIN NO. 1
17 May 2022

Rebid: Supply, Delivery, and Installation of Three (3) Studio Program Hard Sets with Complete Accessories
for Main Studio of People's Television Network Inc.
ITB NO. 2022-0016

This bulletin is being issued to revise/clarify certain portions of the bidding documents. This shall form an integral part of the bidding document for the above-stated project.

No.	Comments/Queries/Concerns	Response
1	During the project implementation, may we request the Building guidelines and health protocol?	The winning bidder shall enforce the following precautionary measures among themselves during the contract implementation: <ul style="list-style-type: none">• Observe physical distancing.• Present a COVID-19 vaccination card or any proof of COVID-19 vaccination• Wear face mask (at least 3-ply surgical mask, preferably N95 mask) and face shield at all times.• Submit duly accomplished Health Declaration form.• Follow Health Protocols set by the Local Government Unit (LGU)
2	May we request a clear copy of General Description of Public Briefing Set	You may access a clear copy of the General Description of the Set through this link
3	Is the 30 day duration inclusive of drawings, materials/specs approval?	Yes, as stated in the TOR's Schedule of Requirements.
4	Lay-outs, shop drawings will be done by contractor, PTNI will provide concepts only?	Yes, Lay-outs, shop drawings will be done by the winning bidder
5	Kindly confirm if TV and brackets will be provided by client	Yes. TV and Brackets shall be provided by the winning bidder
6	May we ask the Light Temperature/Lux Level of the Studio	Lux Level: 800 lux at f4 opening, Temperature: 4500 - 6500K
7	What is the RCP circuit assumption or requirement	It depends on the capacity of the equipment to be used. Further details will be discussed during the contract implementation
8	Where are the Electrical tapping points	This will be discussed during the contract implementation
9	Is there move management or demolition works on existing site condition?	None.
10	Location of utility power breaker?	This will be discussed during the contract implementation



PEOPLE'S TELEVISION
P A R A S A B A Y A N

People's Television Network, Inc
Broadcast Complex, Visayas Avenue, Diliman, Quezon City 1100
Telephone No. 3453-1097 /www.ptv.ph

11	What is the allotted utility power capacity for studio?	It depends on the capacity of the equipment to be used. Further details will be discussed during the contract implementation
12	Are we allowed to do chipping works to relocate pop-up outlet?	No.
13	Please confirm if you need a totally movable and can assemble/disassemble hard sets?	Yes. The Sets shall be movable and can assemble/disassemble. The studio used for these sets are also used in other functions.
14	Do we need power meter for the construction power supply?	Yes.
15	Please confirm if we dont need to dismantle and demolish stages, walls or partition since your going to provide a clear/blank space area.	No need to dismantle stages.

All other information in the Bidding Documents inconsistent with the above is hereby revised accordingly. All other provisions which are not affected shall remain in effect.

For further guidance and information of all concerned.

Thank you.


ATTY. JASON SHAHEER H. SALENDAB
Chairman
Bids and Awards Committee