



PEOPLE'S TELEVISION

REQUEST FOR QUOTATION

(3rd posting)

RFQ No. 2023 – 026

17 October 2023

The People's Television Network, Inc. (PTNI), through its Bids and Awards Committee (BAC), intends to procure the following item/s in accordance with **Section 53.9 Small Value Procurement** of the 2016 revised Implementing Rules and Regulations of the Republic Act No. 9184.

Name of Project	Supply, Delivery, Replacement, Installation, Testing, Commissioning of Various Parts of Defective Generator Set, and Synchronization of Two (2) 501KW Generator Sets for PTNI Manila.
Approved Budget for the Contract (ABC)	Three Hundred Seventy-Four Thousand One Hundred Thirty-Three Pesos (Php374,133.00)
Source of Fund	Corporate Budget

Please submit your quotations/proposals duly signed by you or your duly authorized representative for the item described herein, subject to the Terms and Conditions provided in this RFQ along with the following documents:


1. Duly accomplished quotation/proposal.
2. Duly accomplished conformity with technical specifications.
3. PhilGEPS Registration Number or PhilGEPS Certificate of Registration.
4. Valid Business/Mayor's Permit
5. Duly signed and notarized Omnibus Sworn Statement and, if applicable, notarized Secretary's Certificate in case of corporation, partnership, or cooperative (if available).

Note: If not available during the submission of offer, duly signed and notarized Omnibus Sworn Statement and, if applicable, notarized Secretary's Certificate in case of corporation, partnership, or cooperative shall be submitted before issuance of Notice of Award.

Sealed quotations/proposals may be submitted on or before 10:00am, 25 October 2023, at the Purchasing Office, People's Television Network, Inc., 3rd Floor, Broadcast Complex, Visayas Avenue, Diliman, Quezon City.

The PTNI reserves the right to accept or reject any bid to annul the bidding process and to reject all bids at any time prior to contract award without thereby incurring any liability to the affected bidder or bidders.

For any clarification, please feel free to contact **Ms. Melissa N. Galvez** at this number **+63 917-5864-993**.


BENJAMIN J. ASAKIL
Chairperson, Bids and Awards Committee



PEOPLE'S TELEVISION

Conformity with Technical Specifications

INSTRUCTIONS:

1. Accomplish this part of RFQ correctly and accurately.
2. Do not alter the contents of this form in any way.
3. Please indicate "complied" or "not complied"

Description	Statement of Compliance (Please indicate "complied" or "not complied")
SOLENOID STATIC RELAY	
3050692, 586 114112 6A Coil 24VDC	- 1 pc.
GENERATOR CONTROLLER	
DSE 8610-MKI A/S Load Share DC Supply: 8V to 35V, 0.5A max. DC Output: 24V, 15A (4-5) 2A (8-13) DC Input: 30V Max. Volts free output: 250Vac, 8A AC Voltage Input: 600Vac, 50/60Hz 1-3PH AC Current Input: 5A, 50/60Hz 1-3 PH Charge Alternator: 30V, 2.5W max. Magnetic Pick-up: 70V, 10KHz max. Analog Input: 10V Max. Comms Port: 5V Max.	- 1 unit
BATTERY TRICKLE CHARGER	
BAC2410 Input Nominal AC Voltage: AC (100-277V) Max AC Voltage: AC (90-305V) AC Frequency: 50Hz/60Hz Max. On-load Current: 340W Max. Current: 4A Efficiency: AC 220V Output No Load Voltage: 27.6V, (error±1%) Rated Charging Current: 10A, (error±2%) Max. Output Power: 290W	- 1 lot
SYNCHRONIZATION	
Generator Set	- 2 units



PEOPLE'S TELEVISION

INSTALLATION and COMMISSIONING

Generator Controller:

1. Be sure that the parts provided must be the same specification as in the original parts.
2. The controller brand / model / program / data must be the same as the Gen Set 1 controller.
3. Calibration of program is necessary if needed.

Battery Trickle Charger:

1. Battery charger must be fit on the control panel.
2. Automatic battery charging must be two stage charging process (first constant current, then constant voltage).
3. Suitable for 24volts storage battery and the rated current is 10A.

Scope of Works:

1. Installation and commissioning should be done after sign off.
2. Must finish the repair as per schedule and don't leave the unit not operational.
3. Replace corroded or worn-out electrical field wirings / cables if necessary.
4. After all parts have been replaced and installed the generator should be operate in accordance with its original or normal operation.
5. In case there are other parts found to be for replace and not included on the terms of reference, it is subject for separate quotation.
6. In case the new parts found defective or damaged during the installation, testing, and commissioning within the warranty period, it must replace with a new item.
7. Minor repair on other parts must include on the contract.
8. Initial start-up and testing.
9. Final testing.
10. Synchronization.
11. Submit certificate of service completion upon completion of service repair installation.
12. Full payment upon completion.

Warranty:

- One (1) year warranty on workmanship and supplied items.

Delivery, Installation, Testing, and Commissioning:

- Delivery of module (order abroad) – 30 calendar days upon receipt of Notice to Proceed.
- Installation, testing, and commissioning – seven (7) days. Depends on the end-user and engineering given schedule. (Not included on the delivery date of the module).

Terms of Payment:

- 100% full payment upon completion of installation.

Other specifications can be produced on demand.

Signature over Printed Name

Position/Designation



PEOPLE'S TELEVISION
PARA SABAYAN
QUOTATION/ PROPOSAL

Date:	
Company Name:	
Address:	
Contact No.:	
Email Address:	
Business Permit No.:	
Tax Identification No.:	
PhilGEPS Registration Number:	
Payment Terms:	30 calendar days upon issuance of certificate of service completion and final acceptance.

Quotation/ Proposal (please indicate the kind of goods with the total bid amount and any other related offer)

Qty	Unit	Item Description	Unit Cost	Total Cost
1	pc.	Solenoid Static Relay		
1	unit	Generator Controller		
1	pc.	Battery Trickle Charger		
1	lot	Synchronization		
Total Offered Quotation:				P

General Terms and Conditions:

1. Bidders shall provide the correct and accurate information required in the forms.
2. All price quotations shall be considered as fixed prices and not subject to price escalation during contract implementation.
3. Quotations exceeding the Approved Budget for the contract shall be rejected.
4. Award of contract shall be made to the lowest quotation which complies with the technical specifications and terms and conditions stated herein.
5. Any interlineations, erasures, or overwriting shall be valid only if they are signed or initiated by you or your duly authorized representative.
6. The PTNI shall have the right to inspect the goods to confirm their conformity to the technical specifications once delivered.
7. All items should be delivered within the period specified in the Purchase Order / Job Order.
8. Liquidated damages equivalent to one-tenth of one percent (0.001%) of the value of the goods not delivered within the prescribed delivery period shall be imposed per day to day.
9. Indicate warranty period in cases of equipment or whenever applicable.
10. Delivery Period is within thirty (30) calendar days from receipt of Notice to Proceed.

Signature over Printed Name

Position/Designation