

BID BULLETIN NO. 1
20 November 2023

Supply, Delivery, Installation, Testing, and Commissioning of One (1) Unit of 75 kVA Prime Power Silent Type Generator Set including Training of Personnel for PTV Cordillera Station

ITB NO. 2023-0005

This bulletin is being issued to revise/clarify certain portions of the bidding documents. This shall form an integral part of the bidding document for the above-stated project.


No.	Queries	Response
1	With the existing generator set, may I ask what is the capacity of the genset? Do we need to install this unit to the new site location?	The capacity of the existing generator set is 75 KVA <i>Single Phase</i> . <i>Yes, the existing generator set shall be installed to PTV Cordillera Broadcast Hub, Romulo Drive, Barangay Lualhati, Baguio City.</i>
2	Do we need to supply a brand new Manual Transfer Switch (MTS)/ Automatic Transfer Switch (ATS)? The reason I asked is because it was not indicated in the TOR/Technical Specification	Yes, a new MTS is required. MTS Specifications MTS Dimensions: 100X340X390 175 A
3	Do you require to physically inspect the site? Is site inspection part of the documentary requirement (Site Inspection Certificate)? If so, what or when is the best time to conduct the inspection?	<i>Please see Annex "A"</i>
4	In the technical specifications, it states that your requirement for the new generator set is in 3 Phase. Then by checking with the existing generator set, it is in single phase. I just wanted to verify which phase is really required, kindly confirm	Yes, the new generator set shall be in three (3) phase.

	which is correct? Just a precaution, to avoid any confusion or problem in the implementation of the project.	
5	What cables are we going to use, the existing or we need to provide a new one?	The bidder shall provide cables.

All other information in the Bidding Documents inconsistent with the above is hereby revised accordingly. All other provisions which are not affected shall remain in effect.

For further guidance and information of all concerned.

Thank you.



BENJAMIN J. ASAKIL
Chairperson, Bids and Awards Committee



ANNEX "A"

Site Inspection

The site inspection is scheduled on 21 November 2023, 8:00 AM at Petron Station at Junction Marcos Highway. Interested bidders shall confirm intent to participate by sending a letter to bacsecretariat@ptni.gov.ph before the scheduled date of site inspection.

Please be informed that, Sto Tomas area has an uphill terrain. It is highly recommended to use a 4x4 vehicle.

Engr. James Ewald Tuanquin will serve as PTNI's representative, which you may contact at (0976) 221 2651. Interested Bidders shall enforce minimum health protocols among themselves.

The certificate of Site Inspection will be signed by the PTNI's representative after the activity, which shall be required to include in the bid tender (Technical Component).